

**PER FORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

No 255

Dated 12.03.2025

It is certified that an inspection team headed by Sri Rakesh Kumar Ranjan (Name of officers with designation) from SDO Public Health Sub Division, Darbhanga (Name of Department / office) inspected the **Mahatma Gandhi Shikshan Sansthan , Wajitpur , Bahadurpur Darbhanga** (Name & Address of the School) 12.03.2025 (Date of inspection) has safe drinking water Facilities for the students and members of staff of the Institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/ State/ U.T Govt.

The above valid for a period of one Year

Signature with seal

Rakesh Kumar Ranjan
12/03/25

Sub-Divisional Officer

Name & Address of the office/ Department:-

Public Health Sub-Division
Darbhanga

To

The Principal
Mahatma Gandhi Shikshan Sansthan
Wajitpur , Bahadurpur Darbhanga

District Level water Testing Laboratory Darbhanga DLWTL

Government of Bihar

Public Health Engineering Department

District Name: Darbhanga

Sample No. 22

Sample Collected On- 3/01/2025

Sample No. 22

SL. No.	Block	Panchayat	Village	Location of Source	Parameters															Remarks
					pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO3	SO4	F	As	Total Coli	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	20
1	Bahadurpur	Wajitpur (Near BMP - 13) Darbhanga	Milki Chak	Mahatma Gandhi Shikshan Sansthan	7.46	NT	455	296	158	48	9.12	64	176	NT	NT	NT	NT	NT	NT	
	Desirable limit				6.5	5.0	-	500	200	75	30	250	200	0.3	45	25	1.0	0.01		-
	Permissible limit				8.5	10.0	-	2000	600	200	100	1000	600	1.0	NR	400	1.5	NR	**	-

BDL- Below Deduction Limit

NT- Not Test

[Signature]
12.03.2025
Chemist
P.H Division Darbhanga